

356 MM X 305 MM (14" X 1: RE: M2.2 FOR CONTINUATION.
FURNISH 25 MM (1") FILTER FFAN FROM ABOVE.

12") EXHAUST DUCT UP IN CHASE TO ROOF.

INSULATED DUCT PANEL.

EXTEND 1016mm X 609mm (4 SUPPLY AND 1117mm X 660m SHAFT. FURNISH FIRE/SMOKE D

m (40" X 24") FLAT OVAL MEDIUM PRESSURE \$60mm (44" X 26") RETURN DUCTS UP IN KE DAMPER AT PENETRATION OF SHAFT.

PING FROM CU-1, RE: M2.2. ROUTE AND SIZE REQUIREMENTS.

NEW LOUVER SHALL BE PLACED IN EXISTING WINDOW OPENING. MINIMUM SIZE SHALL BE 1067mm X 914mm (42" X 36"). COORDINATE EXACT LOUVER SIZE WITH WINDOW OPENING. EXTEND 1067mm X 508mm (42" X 20") DUCT FROM LOUVER TO OSA PLENUM. FURNISH 2" FILTER FRAME BEHIND LOUVER WITH BOTTOM ACCESS.

ROUTE 32mm (1-1/4") TYPE DWV COPPER CONDENSATE DRAIN EXISTING FLOOR SINK.

REMOTE MOUNT AHU-1 SUPPLY AND RETURN FAN VFD ON WALL.

CONTROLS CONTRACTOR SHALL FURNISH DDC CONTROLS CABINET.

LINE TO

SHEET

NOTES:

LOUVER SHALL BE MINIMUM 2388mm X 1829mm (94" X 72").
COORDINATE EXACT SIZE WITH UNIT PROVIDED. FURNISH HINGED LOUVER
TO ALLOW FOR FUTURE EQUIPMENT REMOVAL. CONSTRUCT REMOVABLE
PLENUM BEHIND LOUVER, MINIMUM SIZE SHALL BE 2286mm X 1067mm
(90" X 42"). BLANK OFF REMAINING LOUVER WITH INSULATED DUCT

GENERAL NOTES:

- ROUTE DUCTWORK IN COORDINATION WITH OTHER TRADES. HOLD DUCTWORK AS HIGH AS POSSIBLE AND ROUTE DUCTWORK WITH IN STRUCTURE WHERE POSSIBLE.
- UNLESS OTHER WISE NOTED SUPPLY DUCT UPSTREAM OF AFCV IS THE SAME SIZE AS THE DOWN STREAM DUCTWORK. FOR CLEARLY NOT ALL SIZES HAVE BEEN SHOWN.

- DUCT SIZES INDICATED FOR CONNECTION TO EQUIPMENT MAY DIFFER FROM EXACT UNIT CONNECTION DIMENSIONS. PROVIDE ALL NECESSARY TRANSITIONS FROM DUCT SIZES LISTED TO UNIT CONNECTION.

TEMPERATURE SENSORS SHALL BE INSTALLED AT 48" AFF UNLESS NOTED OTHERWISE. COORDINATE JUNCTION BOX INSTALLATION WITH ELECTRICAL CONTRACTOR.

FIRE DAMPERS SHALL BE 1-1/2 HOUR RATED UNLESS OTHERWISE NOTED.

CONTRACTOR SHALL PROVIDE ALL NECESSARY TRANSITIONS TO AVOID CONFLICT WITH OTHER DUCTWORK, PIPING, STRUCTURE, ETC. AS PART OF THIS CONTRACT. WHEREVER AVAILABLE SPACE ALLOWS, OFFSETS SHALL BE MADE WITH 45 DEGREE ELBOWS WITH TURNING VANES.

DUCTWORK AND PIPING SHOWN ARE FOR GENERAL ROUTING PURPOSES ONLY. CONTRACTOR SHALL CONFIRM EXACT ROUTING WITH OTHER TRADES AND PROVIDE ALL NECESSARY TRANSITIONS, HIGH POINT VENTS AND LOW POINT DRAINS AND OFFSETS NECESSARY TO INSTALL A COMPLETE AND FUNCTIONING SYSTEM.

HE CEILING SPACE FROM THE BOTTOM OF THE CEILING GRID TO A MINIMUM OF 6". BOVE THE BOTTOM OF THE CEILING GRID IS RESERVED FOR INSTALLATION OF EILING MOUNTED ITEMS (I.E. LIGHT FIXTURES, SPEAKERS, DIFFUSERS). NO PIPING, UCTWORK, CONDUITS, ETC., EXCEPT DROPS SERVING THE CEILING MOUNTED ITEMS, ALLOWED TO BE INSTALLED IN THIS SPACE, UNLESS OTHERWISE APPROVED BY HE RESIDENT ENGINEER.

NITRACTOR IS REQUIRED TO FOLLOW ALL OSHA REGULATIONS CONCERNING ISTRUCTION. THE SUPERINTENDENT IS REQUIRED TO HAVE COMPLETED, AS A IMUM, OSHA'S 10-HOUR TRAINING AND BE KNOWLEDGEABLE OF GENERAL ETY REQUIREMENTS FOR CONFINED SPACES, FALL PROTECTION, PERSONAL STECTIVE EQUIPMENT, TRENCHING, SCAFFOLDING, CRANES, ELECTRICAL, ETC. LICABLE SUBCONTRACTORS ARE TO HAVE A COMPETENT PERSON ON SITE WHEN UIRED BY OSHA.

PIPING PENETRATIONS THROUGH RATED ASSEMBLIES SHALL BE FIRESTOPPED IN ACCORDANCE NFPA-90A.

TRANSITION AS NECESSARY FRODUCT CONNECTION.

M DUCT SIZES INDICATED ON PLAN TO EQUIPMENT

BE PROVIDED WITH 4-WAY THROW PATTERN UNLESS

ALL CEILING DIFFUSERS SHALL OTHERWISE NOTED.

IF ACCESSING A CONFINED SPACE, THE CONTRACTOR IS REQUIRED HAVE THEIR OWN CONFINED SPACE AIR MONITOR AND TO TEST THE AIR PRIOR TO ENTERING ANY CONFINED SPACE AIR MONITOR AND TO TEST THE AIR PRIOR TO ENTERING AND CONFINED SPACE. IF THE CONTRACTOR MUST ENTER A SANITARY SEWER MANHOLE, IN ADDITION TO A CONFINED SPACE AIR MONITOR, THEY MUST HAVE PROPER OSHA RESCUE EQUIPMENT FOR A PERMIT REQUIRED CONFINED SPACE. WHERE IT IS NOT POSSIBLE FOR THE VA TO SHUTDOWN AN ELECTRICAL PANEL OR CIRCUIT, THE CONTRACTOR MUST PROVIDE AND USE THE APPROPRIATE SAFETY CLOTHING AND EQUIPMENT AS REQUIRED BY NFPA 70E. THE VA WILL BE MONITORING THE CONTRACTOR'S COMPLIANCE WITH OSHA REGULATIONS. FAILURE TO COMPLY IS GROUNDS FOR STOPPING WORK.

P.

AT 48" AFF COORDINATE LOCATION OF TEMPERATURE PLUMBING CONTRACTOR.

DEPARTMENT OF VETERANS AFFAIRS

IDAHO

RME

DJH

M2.

33

<u></u>

03/03/11